

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Tarkett

30000 Aurora Road, Solon, OH, United States

For the following product(s):

Linoleum:

Acoustic Cork Essenza xf², Acoustic Cork xf², Ecopure, Essenza 2.5mm, Etrusco xf², Lenza xf², Linoleum Conductive xf², Linoleum xf² SD 2.5mm, Linosport Classic 4.0mm, Linosport xf² 3.2mm, Narnidur, Sicuro xf² R10, Veneto Acoustiflor xf², Silencio xf², Style Elle xf², Style Emme xf², Tonali xf², Turon, Veneto Acoustic xf², Veneto Tiles xf², Veneto xf², Veneto xf² Bfl

This product meets all of the necessary qualifications to be certified for the following claim:

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v3.0

Conforms to the CDPH/EHLB Standard Method v1.1-2010 (California Section 01350), effective January 1, 2012, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.1-2010)

Registration # SCS-FS-02749

Valid from: July 1, 2016 to June 30, 2017

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI ACCREDITED PROGRAM
PRODUCT CERTIFICATION
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA